

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08284
Name of Facility: Hammocks Middle School
Address: 9889 Hammocks Boulevard
City, Zip: Miami 33196

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: M-DCSB Food and Nutrition
PIC Email: nbonilla@dadeschools.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 5/25/2023

Begin Time: 12:45 PM
End Time: 01:15 PM

Additional Information

FEMALES 257
MALES 331

CENSUS 588

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>OUT</u> 12. Toilet Facilities	SAFETY
<u>NO</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>OUT</u> 22. First Aid Kit
<u>NO</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>NA</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: *IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory

Email Address(es) : ;
nbonilla@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Observed the following areas with missing or water-stained ceiling tiles: room 201, outside area of second floor bathrooms, 3rd floor hallways. Provide missing tiles and replace water-stained tiles.

Observed burnt out lights in the following bathrooms: 223 and 224. Replace burnt-out light bulbs.

Observed hole in floor tiling in room 201. Replace damaged floor tile.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

Observed out of order toilet in boys 1st floor bathroom, 207, and 224 bathroom. Repair out of order toilets.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #22. First Aid Kit

Observed the following expired items in the first aid kit:

Swan Hydrogen Peroxide 12/2022
Aspirin 12/2022

Discard expired items. Corrected on site (COS).

CODE REFERENCE: 22. First Aid Kit. 5(11)(i) SREF. First aid kits shall be fully equipped per Board policy 5(1)(e)10 and available for student use.

Inspection Conducted By: Raad Farhang (913251)
Inspector Contact Number: Work: (305) 623-3575 ex.
Print Client Name:
Date: 5/25/2023

Inspector Signature:

Client Signature: